## **Model CB Boilers**



Courtesy of: C3 Surplus LLC Surplus Industrial Superstore 305-428-2777 https://www.c3surplus.com

Firetube Boilers

## Table A2-13. Model CB Boiler Emission Data

POLLUTANT		ESTIMATED LEVELS - UNCONTROLLED		
		NATURAL GAS	NO. 2 OIL <sup>B</sup>	NO. 6 OIL <sup>C</sup>
СО	ppm <sup>A</sup>	200	90	95
	Lb/MMBtu	0.15	0.07	0.075
NOx	ppm <sup>A</sup>	100	185	502
	Lb/MMBtu	0.12	0.25	0.67
SOx	ppm <sup>A</sup>	1	278	278
	Lb/MMbtu	0.001	0.52	0.52
HC/VOCs	ppm <sup>A</sup>	40	50	70
	Lb/MMBtu	0.016	0.025	0.035
PM	ppm <sup>A</sup>	-	-	-
	Lb/MMBtu	0.01	0.025	0.160

## NOTES:

Refer to Section E for detailed emission information.

A. ppm levels corrected to 3% O<sub>2</sub>, dry basis.

B. Based on fuel constituent levels of:
Fuel-bound nitrogen content = 0.05% by weight
Sulfur content = 0.5% by weight
Ash content = 0.01% by weight
C. Based on fuel constituent levels of:
Fuel-bound nitrogen content = 0.7% by weight
Sulfur content = 0.5% by weight
Ash content = 0.1% by weight
Conradson carbon residue = 16% by weight

